

National Grid's use of Emergency Diesel Standby Generator's in Dealing with Grid Intermittency and Variability Potential Contribution in Assisting Renewables

David Andrews, Senior Technical Consultant, Biwater Energy.

(A talk originally given by as the Energy Manager at Wessex Water at an Open University
Conference on Intermittency, 24th Jan 2006)

Wessex Water – Overview

- One of ten water and sewerage companies in England and Wales
- Over 10,000 square km's area
- Overall performance recognised independently as one of the best




LOCATION & CUSTOMER BASE

2.5m sewerage
individuals

- 1.35m sewerage
only

- 1.1m water and
sewerage

- 0.13m water
only



Wessex Water – Overview

Water Supply

- ❖ **123 treatment plant, 366 pumping stations**
- ❖ **11,000 km's water main**

Wastewater

- ❖ **392 treatment plant, 1,314 pumping stations**
- ❖ **15,000 km's sewers**

Wessex Water – Energy costs

- Energy is one of the largest operational costs
 - average electrical use is about 27 MW
 - = one 747 jet engine output
 - = 0.06% of UK average demand of 39 GWe
 - Clean Water treatment and supply ~ £4 - 8m
 - Wastewater collection and treatment ~ £6 - 10m
- about 4.5 MW continuous biogas CHP generation
- About 32 standby diesel engines, totaling 18 MW used routinely to support National Grid, 4 minute start up and paralleling.

How Are Diesels Presently Used to Assist With Intermittency?


- **NGT Frequency Service Participants**
- **NGT Reserve Service Participants**

NGT Frequency Service

- **NGT Frequency Service** participants - these are large users such as steel works, cold stores, who are happy to be paid to shut off instantaneously whenever grid frequency starts to fall using frequency sensitive relays
- Contracted to stay off for 20 minutes

NGT Reserve Service


- **NGT Reserve Service** participants are small diesel (such as us) and gas turbine generators, etc who are paid to start up and connect to the grid within 20 minutes whenever **Frequency Service** customers are called.
- Must be reliable and able to stay on and run for an hour or so.




Real Time Frequency Data - Last 60 Minutes 19th Feb 2008 - 1800



Electricity demand - Last 8 Days



Real Time Demand Data - Last 60 Minutes



The graph above shows MW demand over the last hour. Please note that the graph refreshes itself every 15 seconds, but may need manually refreshing if left open for a prolonged period.

Context -Types of Capacity on the System

- 57GW in use at peak winter demand
- 1.5 GW of spinning reserve – can come on in 20 – 30 seconds.
- NGT likes to have 8.5 GW additional spare but not running, some of it warming (Down to 4.5GW recently)
- 2.25 GW of Frequency Service loads
- 2.25 GW of Reserve Service diesels etc
- 2 GW? Fast response plant
- Dinorwig and Ffestiniog 2 GW in 15 secs

How Do NGT Reserve Service and Frequency Service cope with Intermittency/Variability?

- Say a 660 MW turbine trips – grid frequency starts to drop
- Under frequency relays on Frequency Service customers trip up to 660 MW of load for up to 20 minutes as frequency falls
- NGT issue Reserve Service start up signal for 660 MW which becomes available within 20 minutes
- When Reserve Service becomes available, Frequency Service loads are re-connected
- Frequency Service relays are then re-armed
- An hour or so later, Frequency Service diesels are replaced with new levels of large power stations and can be stood down

Biggest Source of Intermittency

- Whenever Sizewell B is operating, it is capable of stopping at any time, without warning 1.3GW.
- This is the largest source of intermittency, since it is the largest power generating unit which can be lost, yet NGT readily copes with it using methods outlined over leaf

Wessex Water Diesel Engines

8:55
Wessex Water Power Management System
07/06/2002

Modems
Site Overview
Graphic Display
Site Fuel Status
Site Messages
Alarms
Trends

RS Target load 16,000 KW
 RS generation 0 KW
 Current generation 0 KW
 L.M. Theoretical Power 11,275 KW
 Theoretical Max Power 11,500 KW

Southern 6 MW Declared
 WPD 8 MW Declared

Contact Phone Nos

General Notes

Scomag Notes

Security Access

Log In Log Out

Test Page

✓	06/06/02	15:21:17	GENSET 34 BATTERY CHARGER	FAILED	Modem 1
✓	06/06/02	15:21:17	GENSET 35 AVAILABILITY	UNAVAIL	Modem 2
✓	06/06/02	15:21:17	GENSET 34 AVAILABILITY	UNAVAIL	Modem 3
✓	06/06/02	15:21:17	GENSET 35 PLC	FAILED	Modem 4
					Call Stack

Operator interface page: General Map showing some of the LM sites.

Wessex Water Diesels

32 Sets spread across 24 Sites totalling 18 MW

Site	kW Output	Site	kW Output
Ashford	470	Portbury Wharf	245
Blackwell Hams	480	Radipole 1	675
Chilton Trinity	650	Radipole 2	675
Clevedon	270	Sutton Bingham	690
Durleigh	470	West Huntspill	550
Empool	500	Weston super Mare 1	700
Frome	340	Weston super Mare 2	700
Fulwood	610	Weston super Mare 3	650
Holdenhurst 1	600	Black Rock 1	640
Holdenhurst 3	385	Black Rock 2	640
Minehead 1	260	Corfe Mullen WTW	450
Minehead 2	390	Kingston Seymour 1	640
Poole Inlet	390	Kingston Seymour 2	750
Poole RSPS	800	Weymouth 1	750
Poole BAF	750	Weymouth 2	750
Portishead	380		
Swanage STW	800		

Small set maybe 150kW



Poole inlet pumping station – 390kW + fuel tank



1MW containerised set, fuel in background



Wessex Water Diesel Generator Control System (1)

- This gives one central point of control via a master PLC (small computer) and a PLC retro fitted to each of the generators
- It gives to day visibility of status and permits control and scheduling of each set and reporting of availability to NGT.
- Permits instantaneous start by NGT and constant reporting of output when so doing
- Permits scheduled runs instructed 1-3 hours ahead from **A Large Power Supply Company**

Wessex Water Diesel Generator Control System (2)

- Allows Triad avoidance runs to be instructed 7 hours ahead when Triad warnings are received
- Whenever the system has a run scheduled, the local operators are automatically sent an SMS message telling them that a run is about to start.
- This enables them to monitor it and reminds them to keep their eye on the fuel levels.

Wessex Water Diesel Management System




NGT Computer on the left, operator interface on the right Can dial in remotely via lap top.

Wessex Water Diesel Management System

8:56		1 Alarms		Generator Set Overview				Site Messages		07/06/2002	
O/S Details	Modems	Region Map	System Settings	Graphic Display	Alarms	Trends	X	Next			
Comms	Southern 6 MW Declared						Reserve Service Enabled				
Notes	WPD 8 MW Declared						Actual		0 KW		
Site unavailable Declaration						Possible		0 KW			
Set Identity		Status	Commands	Status	Actual	Possible	Totaliser	Run time			
No 01	Ashford	Available	Stopped	LM	0 KW	500 KW	285.5 MWhr	680 Hrs			
No 02	Blackwell	Unavailable	Stopped	Off Duty	0 KW	165 KW	79.8 MWhr	598 Hrs			
No 03	Chilton Trinity	Available	Stopped	LM	0 KW	620 KW	23.4 MWhr	61 Hrs			
No 04	Clevedon	Available	Stopped	LM	0 KW	270 KW	131.0 MWhr	646 Hrs			
No 05	Durleigh	Available	Stopped	LM	0 KW	450 KW	256.4 MWhr	664 Hrs			
No 06	Frome	Available	Stopped	LM	0 KW	350 KW	184.7 MWhr	693 Hrs			
No 07	Fulwood	Available	Stopped	Off Duty	Note	0 KW	580 KW	366.0 MWhr	813 Hrs		
No 08	Holdenhurst 1	Available	Stopped	LM	0 KW	562 KW	278.1 MWhr	524 Hrs			
No 09	Empool	Available	Stopped	LM	0 KW	500 KW	70.2 MWhr	355 Hrs			
No 10	Holdenhurst 3	Available	Stopped	Off Duty	Note	0 KW	380 KW	1,080.6 MWhr	37,118 Hrs		
No 11	Poole BAF	Available	Stopped	LM	0 KW	750 KW	184.8 MWhr	258 Hrs			
No 12	Minehead	Available	Stopped	LM	0 KW	243 KW	158.5 MWhr	763 Hrs			
No 13	Poole Eastern	Unavailable	Stopped	Off Duty	Note	0 KW	169 KW	75.6 MWhr	404 Hrs		
No 14	Poole Inlet	Available	Stopped	LM	0 KW	382 KW	184.7 MWhr	879 Hrs			
07/06/02 09:42:46 GENSET 25 LOW FUEL LEVEL					ALARM	Modem 1					
✓ 06/06/02 15:21:17 GENSET 21 BLACKLIST					ALARM	Modem 2					
✓ 06/06/02 15:21:17 GENSET 13 BLACKLIST					ALARM	Modem 3					
✓ 06/06/02 15:21:17 GENSET 10 BLACKLIST					ALARM	Modem 4					
✓ 06/06/02 15:21:17 GENSET 2 COMMON FAULT					ALARM	Call Stack					

Operator interface page: Overview Page showing first 14 sets with various status's simulated.


Wessex Water Diesel Management System



4 Modems


Master Control PLC, with its 4 modems.

Wessex Water Diesel Management System



A direct call can be initiated from the NCG SRD dispatch computer.

Wessex Water Diesel Management System



Typical Site: In the background we see the Generator, in the foreground we see the Generator controller and the Load Management control panel.

Wessex Water Diesel Management System



Load Management control panel, with the door open. Showing the PLC controller etc.

Testing Diesels off Load

- This very quickly ruins an engine – maybe in only 50 hours.
- Under loading means low cylinder pressures and poor ring sealing and low temperatures - leading to poor combustion
- Soot forms, clogging rings, and hard carbon scrapes bores
- Injectors clog with soot, un-burnt fuel contaminates oil
- Diesels must be run at full load once a month to ensure they work.
- In 1987 storms, 50% of Thames Water Generators failed to start or stay running.
- *NGT Reserve Service is the ideal way to prove your diesels without destroying them*

Conversion Costs

- Maybe £3k to fit PLC to set
- Paralleling gear (allows grid connection) maybe £5k
- Tidying up set (noise, fuel) maybe £5k

- So for a 1MW set...£13/kW
- 50 kW...maybe £260/kW
- Running costs - fuel 10p/kWh
 - maintenance -0.5p/kWh

How Many Diesels Are There?

- Wessex has 550 generators of capacity 100MW.
- We only use 32 generators of 18MW capacity
- We could use the others but there are diminishing returns – probably still worth doing though.
- Nationally there are up to 20 GW of emergency diesels (EA Technology)
- Large number could be utilised with right incentives
- Over 20 years this technology will become standard

Back up Power Costs - Spark Spread (Gas) and Dark Spread (Coal)

- It's the difference between the cost of fuel, and the selling price of that power from that fuel.
- It is the profit needed to pay off the capital and maintenance cost on the power station.
- You can look up spark spreads on various energy trading web sites - Argus, Spectron etc

Value of Spark Spread and Dark Spread

- Spark spreads are reckoned to need to be about £12/MWh for new gas, and £14/MWh for new coal.
- Presently around £9/MWh
- Present load factor is say 43% then as a whole they would be happy to receive $£9 \times 0.4 = £3.6/\text{MWh}$ for all units supplied for the whole year = 0.36p/kWh

Other Increased Costs From Renewables

- Tuos - Transmission Use of System charges- currently around 0.2p/kWh
- Assume you had to duplicate the entire grid to accommodate wind - still only adds 0.2p/kWh
- Duos - Distribution Use of system charges - would not change - about 0.2p/kWh.
- Bsuos - Balancing Services Use of System - currently around 0.2p/kWh - hard to see why that would get much larger but assume it doubles.

Total Increased Costs of Back Up, Transmission and Balancing

- Spark spreads - 0.36p/kWh
- Doubled Tuos - 0.4p/kWh
- Distribution - no increase
- Bsuos - assume doubles - 0.4p/kWh


- Say 1.2p/kWh - 12%

Other Similar Technologies

- No reason why Frequency Service could not be applied to a 1 kW deferrable load such as freezers, fridges, storage heater, immersion heater in all 20m homes – 20GW
- an efficient, 1 kW Stirling micro-CHP in every home gives 20 GW - Could be on extended Reserve Service

28.5% , HCV efficient Stirling engine

SCP-75 is a carefully designed single-cylinder Stirling cycle engine. The engine is hermetically sealed and has anti-friction bearings which eliminate the need for an oil lubrication system. The Stirling cycle's external combustion and inherently balanced geometry gives the SCP-75 extremely low emission, noise and vibration levels, which will easily meet the stringent environmental demands of the future.




SYSTEM SPECIFICATIONS

Electrical power	3 kW D.C. or A.C.
Heat Power	6 kW as hot water (50–70°C) 1 kW as clean hot air
Fuel consumption	10,5 kW (Higher Calorific Value)
Dimensions	600 mm×400 mm×350 mm



The SCP-75 can be supplied as an integrated CHP unit with pumps, heat exchanger, controllers etc. ready to be installed into a house – effectively a boiler that also produces electricity.



In the CHP (Combined Heat and Power – or co-generation) unit the fuel is converted into electricity, water borne heat and ventilation air which can be used directly for heating.

If you need more information on the SCP-75 unit, please feel free to contact us so that together we can investigate your possibilities to fully exploit the benefits of the SCP-75.

TEM
Malmö Research Center
Nya Agnesstridsvägen 220
S-215 79 MALMÖ
Sweden
Tel. Int. +46 40343401
Nat. 040343401
Fax Int. +46 40948960
Nat. 040948960

